


R-BOX-NEMA3 Installation Instructions - Floor Mounting -




Fix the Floor Mounting Base with expansion screws




Untwist latches to remove the top cover of main cabinet




Fix the main cabinet to Floor Mounting Base with M6 screws.



Place the batteris into cabinet as shown in picture and fix them to cabinet with M6 Screws.




Cabling.




Place and lock the top cover to main cabinet by twisting the latches.


R-BOX-NEMA3 Installation Instructions - Wall Mounting -




Fix the Wall Mounting Base and Wall Mounting Plate to wall with expansion screws by Positioning Board.




Untwist latches to remove the top cover of main cabinet.




Fix the Wall Mounting Adapter to Cabinet with M4 Screws




Install the main cabinet to wall by aligning Wall
Mounting Adapter to Wall
Mounting Plate. Then to fix
the main cabinet to Wall
Mounting Base with M6
Screws.



Place the batteris into cabinet as shown in picture and fix them to cabinet with M6 Screws.



Cabling.



Place and lock the top cover to main cabinet by twisting the latches.

Packing List

NO.	Items	Quantit	Specifications	Pictures
1	Main Cabinet	1pcs	20.9"x15.8"x28.9" 530x400.3x734.7mm	PPE II
2	Floor Mounting Base	1pcs	20.9"x11.9"x2.8" 530x301.2x70mm	
3	Wall Mounting Base	1pcs	20.9"x16.1"x4. 7" 530x409Xx120mm	- IIII IIIIIII
4	Wall Mounting Plate	1pcs	10.6"x0.6"x2.1" 270x15x53mm	
5	Wall Mounting Adapter	1pcs	9.8"x0.8"x1.2" 250x20x30mm	
6	Battery to Busbar Power Cable (Positive)	1pcs	UL10269-4AWG-220mm- Orange-Amphenol 5.7mm Positive+ SC25-6	
7	Battery to Busbar Power Cable (Positive)	1pcs	UL10269-4AWG-310mm- Orange-Amphenol 5.7mm Positive+ SC25-6	
8	Battery to Busbar Power Cable (Negative)	1pcs	UL10269-4AWG-260mm-Black -Amphenol 5.7mm Negative+ SC25-6	
9	Battery to Busbar Power Cable (Negative)	1pcs	UL10269-4AWG-330mm-Black -Amphenol 5.7mm Negative+ SC25-6	
10	Battery to Cabi- net Earthing Cable	1pcs	UL1015-10AWG-250mm Yellow/Green-SC6-6+SC6-6	
11	Battery to Bat- tery Earthing Cable	1pcs	UL1015-10AWG-120mm Yellow/Green-SC6-6+SC6-6	
12	M4 Screw	3 pcs	GB/T 70.3–2000 M4×0.3" (8mm)	
13	M6 Screw	10 pcs	ISO 10644G-2014 M6×0.5"(12mm)	
14	Expansion Screw	12 pcs	GB/T 22795(TCQ)-2008 M8x2.0"(50mm)	
15	Positioning Board	1 pcs	20.9"x28.7"x0.06" 530x730x1.5mm	
16	Warning label	1pcs	2.0"x3.9" 50mmx100mm	! WARNING ELECTRIC SHOCK Only allows professional operation and servicing

